


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:220.09V I:0.1181A P:12.560W PF:0.4833 Freq:50.00Hz Lamp Flux:662.279x1 lm		
NAME: EBM104-08EL-SC27BK	TYPE:固定式灯具	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: WAC Lighting	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 52.73 lm/W			
MODEL		I _{max} (cd)	172.4	S/MH(C0/180)	3.06
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	3.06
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	662.28	η UP,DN(C0-180)	0.1,50.2
NOMINAL FLUX(lm)	662.279	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.1,49.6
LAMPS INSIDE	1	η up(%)	0.2	CIBSE SHR NOM	1.00
TEST VOLTAGE(V)	220	η down(%)	99.8	CIBSE SHR MAX	1.15

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.459m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	138.2	139.4	138.1	139.3	135.5	135.7	132.1	130.4	0- 10	9.550	9.550	1.44,1.44
20	168.6	167.5	167.1	168.1	167.5	169.2	169.4	162.0	10- 20	45.25	54.80	8.28,8.28
30	170.9	170.9	169.9	168.2	167.2	170.2	172.2	163.9	20- 30	77.84	132.6	20,20
40	169.1	170.1	167.1	163.4	161.8	165.7	168.4	160.2	30- 40	105.3	238.0	35.9,35.9
50	158.1	157.8	153.4	150.1	151.6	153.4	155.9	147.6	40- 50	124.1	362.1	54.7,54.7
60	135.6	139.1	135.2	129.7	129.1	132.0	130.8	122.2	50- 60	128.9	491.0	74.1,74.1
70	89.97	88.96	85.13	83.76	81.25	85.15	86.97	80.64	60- 70	109.8	600.8	90.7,90.7
80	18.46	16.75	15.97	15.13	17.30	18.25	22.08	22.26	70- 80	53.60	654.4	98.8,98.8
90	0.1751	0.1820	0.1971	0.1618	0.2255	0.2428	0.2632	0.2192	80- 90	6.857	661.3	99.8,99.8
100	0.0940	0.1048	0.1135	0.0858	0.1256	0.1243	0.1092	0.0819	90-100	0.1575	661.4	99.9,99.9
110	0.0848	0.0981	0.1013	0.0840	0.1032	0.1065	0.0905	0.0744	100-110	0.1016	661.5	99.9,99.9
120	0.1176	0.1272	0.1268	0.1166	0.1339	0.1418	0.1289	0.1146	110-120	0.1073	661.6	99.9,99.9
130	0.1546	0.1641	0.1588	0.1526	0.1935	0.2034	0.1915	0.1794	120-130	0.1349	661.8	99.9,99.9
140	0.1891	0.1941	0.1914	0.1882	0.2485	0.2591	0.2523	0.2409	130-140	0.1537	661.9	99.9,99.9
150	0.2329	0.2369	0.2340	0.2337	0.2896	0.3007	0.2966	0.2827	140-150	0.1523	662.1	100,100
160	0.2633	0.2637	0.2657	0.2647	0.2982	0.3039	0.3003	0.2931	150-160	0.1287	662.2	100,100
170	0.1927	0.1894	0.1908	0.1908	0.2158	0.2170	0.2159	0.2165	160-170	0.0719	662.3	100,100
180	0.2084	0.2013	0.2073	0.2087	0.2063	0.2042	0.2060	0.2078	170-180	0.0195	662.3	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 298.52 lm

%lum = 45.1%

%lamp = 45.1%

Conical surface Flux(120deg): 491.03 lm


%lum = 74.1%

%lamp = 74.1%

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.459m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.459m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

pcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.03	.98	.94	1.01	.97	.93	.96	.93	.90	.92	.90	.87	.89	.87	.84	.82
2.0	.88	.81	.75	.86	.80	.74	.83	.77	.72	.79	.75	.70	.76	.72	.69	.67
3.0	.76	.68	.61	.75	.67	.60	.72	.65	.59	.69	.63	.58	.66	.61	.57	.54
4.0	.67	.57	.50	.65	.56	.50	.63	.55	.49	.60	.53	.48	.58	.52	.47	.45
5.0	.59	.49	.42	.58	.48	.42	.55	.47	.41	.53	.46	.41	.51	.45	.40	.38
6.0	.52	.43	.36	.51	.42	.36	.49	.41	.35	.48	.40	.35	.46	.39	.34	.32
7.0	.47	.37	.31	.46	.37	.31	.44	.36	.31	.43	.36	.30	.41	.35	.30	.28
8.0	.42	.33	.27	.42	.33	.27	.40	.32	.27	.39	.32	.27	.38	.31	.26	.24
9.0	.38	.30	.24	.38	.30	.24	.37	.29	.24	.36	.29	.24	.34	.28	.23	.21
10.0	.35	.27	.21	.35	.27	.21	.34	.26	.21	.33	.26	.21	.32	.25	.21	.19



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

WEC AND CCEC

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.325	.185	.059	.318	.182	.058	.305	.175	.056	.292	.169	.054	.281	.163	.053	
2.0	.311	.171	.052	.305	.168	.052	.293	.163	.051	.282	.158	.050	.272	.154	.048	
3.0	.289	.154	.046	.283	.152	.046	.273	.148	.045	.263	.144	.044	.254	.141	.043	
4.0	.267	.139	.041	.262	.137	.040	.252	.134	.040	.243	.131	.039	.235	.128	.039	
5.0	.246	.125	.036	.241	.124	.036	.233	.121	.036	.225	.119	.035	.218	.116	.035	
6.0	.227	.114	.033	.223	.113	.032	.216	.111	.032	.209	.108	.032	.202	.106	.032	
7.0	.211	.104	.030	.207	.103	.029	.201	.101	.029	.194	.100	.029	.188	.098	.029	
8.0	.196	.096	.027	.193	.095	.027	.187	.093	.027	.181	.092	.027	.176	.090	.026	
9.0	.183	.089	.025	.181	.088	.025	.175	.087	.025	.170	.085	.024	.165	.084	.024	
10.0	.172	.082	.023	.169	.082	.023	.164	.081	.023	.160	.079	.023	.155	.078	.022	

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.192	.192	.192	.164	.164	.164	.112	.112	.112	.064	.064	.064	.021	.021	.021	
1.0	.183	.157	.134	.156	.135	.116	.107	.093	.080	.062	.054	.046	.020	.017	.015	
2.0	.176	.133	.097	.151	.115	.084	.103	.079	.058	.060	.046	.034	.019	.015	.011	
3.0	.169	.116	.073	.145	.100	.063	.100	.069	.044	.058	.040	.026	.018	.013	.009	
4.0	.162	.103	.057	.139	.089	.049	.096	.062	.035	.055	.036	.021	.018	.012	.007	
5.0	.155	.092	.046	.133	.080	.040	.092	.056	.028	.053	.033	.017	.017	.011	.006	
6.0	.148	.084	.038	.127	.073	.033	.088	.051	.024	.051	.030	.014	.016	.010	.005	
7.0	.141	.077	.033	.121	.067	.029	.084	.047	.020	.049	.028	.012	.016	.009	.004	
8.0	.135	.072	.029	.116	.062	.025	.080	.044	.018	.047	.026	.011	.015	.008	.003	
9.0	.128	.067	.025	.110	.058	.022	.077	.041	.016	.045	.024	.009	.014	.008	.003	
10.0	.122	.063	.023	.105	.054	.020	.073	.038	.014	.043	.023	.008	.014	.007	.003	

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	22.6	24.3	22.9	24.5	24.7	22.6	24.2	22.9	24.4	24.7
3H	24.5	26.0	24.8	26.3	26.5	24.4	25.9	24.7	26.1	26.4
4H	25.1	26.5	25.4	26.8	27.0	24.8	26.3	25.1	26.5	26.8
6H	25.2	26.5	25.5	26.8	27.1	24.9	26.3	25.2	26.5	26.8
8H	25.2	26.5	25.5	26.8	27.1	24.9	26.2	25.2	26.5	26.8
12H	25.1	26.4	25.5	26.7	27.0	24.8	26.1	25.2	26.4	26.7
4H 2H	23.4	24.9	23.7	25.1	25.4	23.4	24.8	23.7	25.1	25.4
3H	25.4	26.7	25.8	27.0	27.3	25.3	26.5	25.6	26.8	27.1
4H	26.0	27.1	26.4	27.5	27.8	25.8	26.9	26.2	27.2	27.6
6H	26.2	27.2	26.6	27.5	27.9	25.9	26.9	26.3	27.3	27.6
8H	26.2	27.1	26.6	27.5	27.9	25.9	26.8	26.3	27.2	27.6
12H	26.2	27.0	26.6	27.4	27.8	25.9	26.7	26.3	27.1	27.5
8H 4H	26.1	27.1	26.6	27.5	27.9	25.9	26.9	26.4	27.3	27.7
6H	26.4	27.2	26.8	27.6	28.0	26.1	26.9	26.6	27.3	27.7
8H	26.4	27.1	26.9	27.5	28.0	26.1	26.8	26.6	27.3	27.7
12H	26.4	27.0	26.9	27.5	27.9	26.1	26.7	26.6	27.2	27.7
12H 4H	26.1	27.0	26.6	27.4	27.8	25.9	26.8	26.3	27.2	27.6
6H	26.4	27.1	26.8	27.5	27.9	26.1	26.8	26.6	27.2	27.7
8H	26.4	27.0	26.9	27.5	27.9	26.2	26.7	26.6	27.2	27.7
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.2					+ 0.1 / - 0.2				
1.5H	+ 0.2 / - 0.4					+ 0.3 / - 0.4				
2.0H	+ 0.2 / - 0.6					+ 0.3 / - 0.7				

CIE Pub.117, 662.3 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = -1.4$)

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:


UTILIZATION FACTORS TABLE

REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	52	40	32	52	40	32	50	39	32	25
0.80	63	50	42	62	50	42	60	49	41	34
1.00	72	60	52	70	59	51	68	61	51	43
1.25	79	68	60	78	67	60	75	66	59	51
1.50	85	74	66	83	73	66	80	71	65	57
2.00	93	83	76	91	82	75	87	80	74	66
2.50	97	89	82	95	87	81	91	84	79	70
3.00	101	93	87	99	92	86	94	89	84	75
4.00	105	99	94	103	97	93	98	94	90	81
5.00	108	103	99	105	101	97	101	97	94	85
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended				SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:


ISOCANDELA DIAGRAM



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.2DEG
Operators:Oliver
Test Date:2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:2.459m [K=1.0000]
Remarks:


AAI Figure



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:220.09V I:0.1181A P:12.560W PF:0.4833 Freq:50.00Hz Lamp Flux:662.279x1 lm		
NAME: EBM104-08EL-SC27BK	TYPE:固定式灯具	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: WAC Lighting	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	8898
L_0~180(75)av	6476
L_0~180(85)av	1881
L_90~270(65)av	8883
L_90~270(75)av	6580
L_90~270(85)av	1959
L_45(65)av	8730
L_45(75)av	6406
L_45(85)av	1887

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.459m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.459m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--1

UNIT: cd

C(DEG) γ (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3			
5	86.7	87.9	88.2	88.3	89.0	89.5	88.7	86.8	75.6	74.8	74.8	75.7	75.8	74.6	74.2	76.0			
10	138	139	139	139	138	139	139	139	135	136	136	135	132	130	130	128			
15	163	164	163	163	162	163	164	164	162	163	163	164	162	150	157	155			
20	169	168	167	167	167	167	168	168	168	168	169	170	169	159	162	161			
25	170	170	169	169	169	168	169	168	168	169	170	171	172	164	164	162			
30	171	171	171	171	170	169	168	168	167	168	170	172	172	167	164	162			
35	171	171	172	171	170	167	167	166	165	166	169	171	171	168	163	162			
40	169	169	170	169	167	165	163	163	162	162	166	167	168	166	160	161			
45	165	166	166	164	161	158	158	158	158	158	160	163	164	162	156	158			
50	158	158	158	156	153	151	150	151	152	152	153	155	156	154	148	152			
55	148	150	151	149	147	142	141	142	143	143	145	145	145	144	137	142			
60	136	137	139	139	135	130	130	128	129	130	132	131	131	130	122	130			
65	117	118	118	116	113	110	110	108	109	111	112	112	112	111	103	112			
70	90.0	90.3	89.0	87.1	85.1	84.1	83.8	80.4	81.3	82.5	85.1	86.2	87.0	87.9	80.6	88.0			
75	53.4	52.4	50.2	48.0	47.4	47.3	46.1	45.3	47.1	47.4	49.7	53.3	54.8	56.8	53.0	56.7			
80	18.5	17.5	16.8	16.1	16.0	15.8	15.1	15.6	17.3	17.2	18.3	19.5	22.1	22.6	22.3	22.5			
85	5.13	4.83	4.57	4.28	4.08	4.00	3.89	3.91	4.70	4.93	5.43	5.90	6.17	6.18	5.84	5.94			
90	0.18	0.18	0.18	0.19	0.20	0.20	0.16	0.21	0.23	0.23	0.24	0.26	0.26	0.26	0.22	0.24			
95	0.12	0.13	0.13	0.14	0.14	0.15	0.11	0.16	0.17	0.16	0.16	0.15	0.14	0.13	0.11	0.13			
100	0.09	0.10	0.10	0.11	0.11	0.11	0.09	0.12	0.13	0.12	0.12	0.12	0.11	0.10	0.08	0.09			
105	0.08	0.09	0.10	0.10	0.10	0.10	0.08	0.10	0.10	0.11	0.11	0.10	0.09	0.08	0.07	0.08			
110	0.08	0.09	0.10	0.10	0.10	0.10	0.08	0.10	0.10	0.11	0.11	0.10	0.09	0.08	0.07	0.08			
115	0.10	0.10	0.11	0.11	0.11	0.11	0.10	0.11	0.11	0.12	0.12	0.11	0.11	0.10	0.09	0.09			
120	0.12	0.12	0.13	0.13	0.13	0.13	0.12	0.13	0.13	0.14	0.14	0.14	0.13	0.12	0.11	0.12			
125	0.14	0.14	0.14	0.15	0.14	0.14	0.13	0.15	0.16	0.17	0.17	0.17	0.16	0.15	0.15	0.15			
130	0.15	0.16	0.16	0.17	0.16	0.16	0.15	0.16	0.19	0.20	0.20	0.20	0.19	0.18	0.18	0.18			
135	0.17	0.17	0.18	0.18	0.17	0.17	0.17	0.18	0.22	0.24	0.23	0.23	0.22	0.22	0.21	0.21			
140	0.19	0.19	0.19	0.20	0.19	0.19	0.19	0.19	0.25	0.26	0.26	0.26	0.25	0.24	0.24	0.24			
145	0.21	0.21	0.21	0.22	0.21	0.21	0.21	0.21	0.27	0.28	0.28	0.28	0.28	0.27	0.27	0.26			
150	0.23	0.23	0.24	0.24	0.23	0.23	0.23	0.24	0.29	0.30	0.30	0.30	0.30	0.29	0.28	0.28			
155	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.30	0.31	0.31	0.31	0.31	0.31	0.29	0.29			
160	0.26	0.26	0.26	0.26	0.27	0.27	0.26	0.27	0.30	0.30	0.30	0.30	0.30	0.30	0.29	0.29			
165	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27			
170	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22			
175	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21			
180	0.21	0.21	0.20	0.21	0.21	0.20	0.21	0.21	0.21	0.21	0.20	0.20	0.21	0.21	0.21	0.21			

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-11-22

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.459m [K=1.0000]
 Remarks: